


Output Expansion Module Type ABS CA 781



Copyright © 2023 Sulzer. All rights reserved.

This manual, as well as the software described in it, is furnished under license and may be used or copied only in accordance with the terms of such license. The content of this manual is furnished for informational use only, is subject to change without notice, and should not be construed as a commitment by Sulzer. Sulzer assumes no responsibility or liability for any errors or inaccuracies that may appear in this book.

Except as permitted by such license, no part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means, electronic, mechanical, recording, or otherwise, without the prior written permission of Sulzer.

Sulzer reserves the right to alter specifications due to technical developments.

1 FUNCTION AND USAGE

CA 781 is an IO expansion unit to PC 441 for additional digital and analog output signals. CA 781 expands the PC 441 system with 8 digital outputs and 2 analog output signals.

In order to run more than 2 VFD pumps in a PC 441 system with separate control signals the CA 781 is required. The expansion of 8 digital outputs gives the opportunity to control other equipment in the installation.

2 INSTALLATION

2.1 Mount the controller

Mount the unit on a 35 mm DIN rail. The physical dimensions of the device is: 86 x 70 x 58 mm (3.39 x 2.76 x 2.28 inch) (H x W x D). If it does not easily snap onto the rail, you can pull the small tab at the bottom side of the unit, using a small screwdriver.

2.2 Power supply to CA 781

CA 781 has to be powered from the same source as PC 441 or a separate power supply with common V- with PC 441 in order to secure the functionality. The CAN bus from PC 441 supply is insufficient.

WARNING Ensure that all power is off, and that all output devices to be connected to the controller also are turned off before you connect anything!

The power must be DC between 9 and 34 volts. Figure 1 shows how to connect power and how to connect a battery pack for uninterrupted operation.

For cables longer than 30 m extra surge protection should be mounted where needed.




Figure 1 Power Connection

2.3 Connections

There are a total of 19 terminals that may be connected to power, relays and analog inputs in corresponding devices. These terminals are numbered from 1 to 19 according to the following chart:

Table 1. Connection chart of CA 781

#			Description
1	Ø	↔ →	CAN L
2	Ø	V-	CAN Shield
3	Ø	↔ →	CAN H
4	Ø	→	Analog Output 2 -
5	Ø	←	Analog Output 2 +
6	Ø	→	Analog Output 1 -
7	Ø	←	Analog Output 1 +

8	<input checked="" type="checkbox"/>	V+	Power Supply V+ (+9 – 34 VDC)
9	<input checked="" type="checkbox"/>	V-	Power Supply V-
10	<input checked="" type="checkbox"/>	→	Digital Output 1 +
11	<input checked="" type="checkbox"/>	→	Digital Output 2 +
12	<input checked="" type="checkbox"/>	→	Digital Output 3 +
13	<input checked="" type="checkbox"/>	→	Digital Output 4 +
14	<input checked="" type="checkbox"/>	→	Digital Output 5 +
15	<input checked="" type="checkbox"/>	→	Digital Output 6 +
16	<input checked="" type="checkbox"/>	→	Digital Output 7 +
17	<input checked="" type="checkbox"/>	→	Digital Output 8 +
18	<input checked="" type="checkbox"/>	V-	Common V –
19	<input checked="" type="checkbox"/>	V-	Common V –

2.4 Common for CA 781

CA 781 is in need of extra current because it also supplies the analog and the digital outputs. Therefore it is important that the unit is supplied by a separate power supply or powered direct from the source of PC 441 supply if it is sufficient. See section 3 Technical data table for power consumption.

Power LED When unit is powered up and running the green power LED will be lit.

CAN LED See chapter about CAN.

Digital outputs Every output has its own LED which lights then it's active.

2.5 CAN

A CAN network is of multi drop type which means that all units are connected in parallel on the same cable. In a CAN network every unit must have a unique address or ID-number.

On the CA 781 the CAN ID is fixed. If the device has contact with the network master, the CAN LED is fixed green. If the CAN LED is blinking, then the connection to the master is lost. For error codes of the CAN LED see system manual.

2.6 CAN Cable Termination

The CAN bus must be terminated at both cable ends.

If used, PC 441 is bus master and has a built-in termination that is always active and should therefore always be placed at one of the endpoints of the cable. For other devices you can activate the selectable termination with a switch, marked "CAN term". Activate termination for the device placed on the other endpoint of the cable. All other devices between should have their termination switch in "OFF" position.




Figure 2 CAN network with connections

2.7 CAN Connections

The CAN cable uses 3 wires. Two wires are used for communication CAN_L and CAN_H and one wired is shield CAN_SHLD.

NOTE! Bus power is not allowed on CA 781.

The connections are prepared to be done by screw plug in connectors.

Table 2. CAN connection at Top Side

#			Usage
1	(\otimes)	\longleftrightarrow	CAN L
2	(\otimes)	V-	CAN Shield
3	(\otimes)	\longleftrightarrow	CAN H

2.8 Digital Output

There are 8 digital outputs which are working as positive logic. That means that when the digital output is active the LED for corresponding output lights up and the voltage of the output is equivalent to the power supply voltage.




Figure 3 Digital output connection (external relay)

NOTE! 8 Digital Output as positive logic, sourcing from power supply 1A/output.
Max total current for all 8 outputs together is 4 Ampere.

2.9 Analog Output

There are two analog output signals which support 4 – 20 mA output.




Figure 4 Analog output connection

3 TECHNICAL DATA

3.1 Technical data CA 781

Ambient operation temperature	-20 to +50 °C (-4 to +122 °F)
Ambient storage temperature	-30 to +80 °C (-22 to +176 °F)
Degree of protection	IP 20, NEMA: Type 1
Housing material	PPO and PC
Pollution degree	2
Installation category	CAT II
Flame rate	V0 (E45329)
Humidity	0-95 % RH non condensing
Mounting	DIN Rail 35 mm
Dimension (HxWxD)	86 x 70 x 58 mm (3.39 x 2.76 x 2.28 inch) Plug in connectors will add 2 x 9.5 mm (0.375 inch) to 'H'
Humidity	0-95 % RH non condensing
Power supply	9 – 34 VDC
Power current consumption	< 2.5 W Excluding external loads
Digital outputs Max load	8 DO. Positive logic. Sourcing from power supply Max load 1A/output. Max total current for all 8 outputs together is 4 A.
Analog outputs	2 AO. 4 – 20 mA Sourcing from power supply
Max load	500 ohm@12 V, 1100 ohm@24 V
Resolution	15 bits 0.4 uA
Current limit	~22 mA
Field Bus	1 CAN Port
Max altitude	Max 2000 MASL or 6562 ft. AMSL
Compliance	

Attention If the unit is used in a manner not described in this document the protection provided by the equipment may be impaired.

3.2 Cleaning

How to clean the unit

Power off the unit. Only outside/front shall be cleaned by using a dry, soft cloth. A good choice would be the microfiber type of cloth. Gently wipe the CA 781 front in order not to scratch the overlay. If the dry cloth did not completely remove the dirt, do not press harder than attempt to scrub it off. If necessary, moisten the cloth by adding a small amount of water with thin solution of mild detergent and try again. Never use detergent with polish or solvent which can have an impact of the plastic surface.

Declaration of Conformity

As defined by:

EMC-Directives 2004/108/EC and 92/31/EEC, Low Voltage Directive 2006/95/EC, Directive for CE-Marking 93/68/EEC

EN	EC Declaration of Conformity	SV	EG-försäkran om överensstämmelse
DE	EG-Konformitätserklärung	NO	EUs Samsvarserklæring
FR	Déclaration de Conformité CE	DA	EC-Overensstemmelseserklæring
NL	EC-Overeenkomstigheidsverklaring	FI	EU-Vaatinmustenmukaisuusvakuutus
ES	Declaración de conformidad CE	ET	EÜ Vastavuse deklaratsioon
PT	Declaracão de conformidade CE	PL	Deklaracja zgodnosti WE
IT	Dichiarazione di conformità CE	CS	Prohlášení o shodě ES
EL	Δήλωση εναρμόνισης EK	SK	EC Vyhlásenie o zhode
TR	AT Uygunluk Beyani	HU	EK Megfelelőségi nyilatkozat

Sulzer Pump Solutions AB, Rökerigatan 20, SE-121 62 Johanneshov, Sweden

- EN: Name and address of the person authorised to compile the technical file to the authorities on request:
 DE: Name und Adresse der Person, die berechtigt ist, das technische Datenblatt den Behörden auf Anfrage zusammenzustellen:
 FR: Nom et adresse de la personne autorisée pour générer le fichier technique auprès des autorités sur demande :
 NL: Naam en adres van de persoon die geautoriseerd is voor het op verzoek samenstellen van het technisch bestand:
 ES: Nombre y dirección de la persona autorizada para compilar el archivo técnico destinado a las autoridades:
 PT: Nome e endereço da pessoa autorizada a compilar o ficheiro técnico para as autoridades, caso solicitado:
 IT: Il nome e l'indirizzo della persona autorizzata a compilare la documentazione tecnica per le autorità dietro richiesta:
 EL: Όνομα και διεύθυνση του ατόμου που είναι εξουσιοδοτημένο για τη σύνταξη του τεχνικού φακέλου προς τις αρχές επί τη απαιτήσει:
 TR: Yetkililer makamlara istek üzerine teknik dosyayı hazırlamaya yetkili olan kişinin adı ve adresi:
 SV: Namn och adress på den person som är auktoriserad att utarbeta den tekniska dokumentsamlingen till myndigheterna:
 NO: Navn og adresse på den personen som har tillatelse til å sette sammen den tekniske filen til myndighetene ved forespørsel:
 DA: Navn og adresse på den person, der har tilladelse til at samle den tekniske dokumentation til myndighederne ved anmodning om dette:
 FI: Viranomaisten vaatiessa teknisten tietojen lomaketta lomakkeen valtuutetun laittajan nimi ja osoite:
 ET: Isiku nimi ja aadress, kelle pädevuses on koostada nõudmisse korral ametiasutustele tehnilist dokumentatsiooni:
 PL: Nazwisko i adres osoby upoważnionej do przygotowania dokumentacji technicznej w przypadku, gdy jest ona wymagana przez władze:
 CS: Jméno a adresa osoby oprávněné na vyžádání ze strany úřadu vytvořit soubor technické dokumentace:
 SK: meno a adresa osoby oprávnené na zostavenie technického súboru pre úradu na požiadanie:
 HU: Asmens, igalioito valdžios institucijoms pareikalavus sudaryti techninę bylą, vardas, pavardė ir adresas:

James Wall, Head of Product Safety and Regulations Flow Equipment, Sulzer Management AG ,
 Neuwiesenstrasse 15, 8401 Winterthur, Switzerland

- | | |
|---|--|
| EN: Declare under our sole responsibility that the products: | SV: Försäkrar under eget ansvar att produkterna: |
| DE: Erklärt eigenverantwortlich dass die Produkte: | NO: Erklærer på eget ansvar, at følgende produkter |
| FR: Déclarons sous notre seule responsabilité que les produits: | DA: Erklærer på eget ansvar, at følgende produkter: |
| NL: Verklaaren geheel onder eigen verantwoordelijkheid dat de produkten: | FI: Vakuutamme yksinomaan omalla vastuullamme, että seuraavat tuotteet |
| ES: Declaramos bajo nuestra exclusiva responsabilidad que los productos: | ET: Deklarerime ainuvastutajana, et tooted: |
| PT: Declaramos sob nossa unica responsabilidade que los produtos: | PL: Deklaruje z pełna odpowiedzialnością, ze urządzenia typu: |
| IT: Dichiariamo sotto la nostra esclusiva responsabilità che i prodotti: | CS: Prohlašujeme na vlastní odpovědnost, že výrobky: |
| EL: Δηλώνουμε με αποκλειστική μας ευθύνη ότι τα προϊόντα: | SK: Vyhlásujeme na našu zodpovednosť, že výrobky: |
| TR: Sorumluluk tamamen bize ait olarak beyan ederiz ki aşağıdaki ürünler: | HU: Felelősséggünk teljes tudatában kijelentjük, hogy a termékek: |

ABS control panel CA 781

- EN: to which this declaration relates are in conformity with the following standards or other normative documents:
 DE: auf die sich diese Erklärung bezieht, den folgenden und/oder anderen normativen Dokumenten entsprechen:
 FR: auxquels se réfère cette déclaration sont conformes aux normes ou à d'autres documents normatifs:
 NL: waarop deze verklaring betrekking heeft, in overeenstemming zijn met de volgende normen of andere normatieve documenten:
 ES: objeto de esta declaración, están conformes con las siguientes normas u otros documentos normativos:
 PT: aque se refere esta declaração está em conformidade com as Normas our outros documentos normativos:
 IT: ai quali questa dichiarazione si riferisce sono conformi alla seguente norma o ad altri documenti normativi:
 EL: τα οποία αφορά η παρούσα δήλωση είναι σύμφωνα με τα ακόλουθα πρότυπα ή άλλα κανονιστικά έγγραφα:
 TR: bu beyanın konusunu oluşturmakta olup aşağıdaki standart ve diğer norm belgelerine uygundur:
 SV: som omfattas av denna försäkran är i överensstämmelse med följande standarder eller andra regelgivande dokument:
 NO: som dekkes av denne erklæringen, er i samsvar med følgende standarder eller andre normative dokumenter:
 DA: som er omfattet af denne erklæring, er i overensstemmelse med følgende standarder eller andre normative dokumenter:
 FI: joihin tämä vakuutus liittyy, ovat seuraavien standardien sekä muiden sääntöämäärävien asiakirjojen mukaisia:
 ET: mida käesõpev deklaratsioon puudutab, on vastavuses järgmiste standardide ja muude normatiividokumentidega:
 PL: do których odnosi się niniejsza deklaracja sa zgodne z nastepującymi normami lub innymi dokumentami normatywnymi:
 CS: na které se toto prohlášení vztahuje, jsou v souladu s následujícími normami nebo jinými normativními dokumenty:
 SK: na ktoré sa vz ahuje toto vyhlásenie, zodpovedajú nasledujúcim štandardom a iným záväzným dokumentom:
 HU: amelyekre ez a nyilatkozat vonatkozik, megfelelnek a következőszabványokban és egyéb szabályozó dokumentumokban leírtaknak:

Safety: EN 61010-1:2001

EMC: EN 61000-6-1:2001, EN 61000-6-2:2003, EN 61000-6-3:2001, EN 61000-6-4:2001

Brendan Sinnott, General Manager, Sulzer Pump Solutions Ireland Ltd. Wexford. 31.07.2023

UKCA Declaration of Conformity

Manufacturer: Sulzer Pump Solutions Ireland Ltd.
Address: Clonard Road, Wexford, Ireland

Declare under our sole responsibility that the product:

ABS control panel CA 781

To which this declaration relates is in conformity with the following standards or other normative documents as defined by:


Electromagnetic Compatibility Regulations 2016, S.I. 2016 No 1091

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012, S.I. 2012 No 3133

BS EN 61010-1:2001, BS EN 61000-6-1:2001, BS EN 61000-6-2:2003, BS EN 61000-6-3:2001, BS EN 61000-6-4:2001



Brendan Sinnott
General Manager,
Sulzer Pump Solutions Ireland Ltd.
Wexford
07.04.2022



SULZER

Sulzer Pump Solutions Ireland Ltd., Clonard Road, Wexford, Ireland
Tel. +353 53 91 63 200, www.sulzer.com